

VersaPro™

Packaged Heat Pump Installation Manual

MODELS:

- MPH241H413B
- MPH301H413B
- MPH361H413B
- MPH421H413B
- MPH481H413B
- MPH601H413B



Read this manual carefully before installation and keep it where the operator can easily find it for future reference.

Due to updates and constantly improving performance, the information and instructions within this manual are subject to change without notice.

Version Date: 07/16/24

Please visit www.mrcool.com/documentation to ensure you have the latest version of this manual.



CONTENTS

1 SAFETY	2
2 INSTALLATION	3
2.1 Inspection	3
2.2 Limitations	3
2.3 Pre-Installation Checks	3
2.4 Rigging & Handling	3
2.5 Unit Information & Dimensions	4
2.6 Clearances	9
2.7 Ductwork	9
2.8 Condensate Drain Pipe	10
2.9 Filters	10
3 ELECTRICAL WIRING	10
3.1 Electrical Wiring Overview.....	10
3.2 Power Wiring.....	10
3.3 Grounding.....	11
3.4 Control Wiring.....	11
4 AIR FLOW PERFORMANCE DATA	15
5 SYSTEM OPERATION	24
5.1 Compressor Crankcase Heater	24
5.2 Protection.....	24
5.3 Defrost Mode Introduction (Heat Pump Only)	25
5.4 Thermostat Signals.....	26
6 OPERATION CHECK-UP	27
6.1 Cooling Startup	27
6.2 Heating Startup	27
7 TROUBLESHOOTING	27
7.1 Fault Code of Motor Driver Module	27
7.2 Fault Code of Main Control Module	27
7.3 Troubleshooting Table.....	28

Safety Precautions

Read Before Using

Incorrect usage may cause serious damage or injury. Keep this manual for future reference. These instructions do not cover all of the different variations of systems nor does it provide for every possible contingency to be met in connection with installation.



Indicates the most serious hazards which will result in severe personal injury, property and/or product damage, or death.



Indicates hazards which could result in moderate personal injury and/or property and product damage.

NOTE

Indicates suggestions which will result in enhanced installation, reliability, or operation.


WARNING

- These instructions are intended as an aid to qualified, licensed service personnel for proper installation, adjustment and operation of this unit. Read these instructions thoroughly before attempting installation or operation.
- Failure to follow these instructions may result in improper installation, adjustment, service or maintenance possibly resulting in fire, electrical shock, property damage, personal injury or death.
- The manufacturer's warranty does not cover any damage or defect to the heat pump caused by the attachment or use of any components, accessories or devices (other than those authorized by the manufacturer) into, onto or in conjunction with the heat pump. You should be aware that the use of unauthorized components, accessories or devices may adversely affect the operation of the heat pump and may also endanger life and property. The manufacturer disclaims any responsibility for such loss or injury resulting from the use of such unauthorized components, accessories or devices.
- Disconnect all power to the unit before starting maintenance. Failure to do so can result in severe electrical shock or death.
- Do not, under any circumstances, connect return ductwork to any other heat producing device such as a fireplace insert, stove, etc. Unauthorized use of such devices may result in fire, carbon monoxide poisoning, explosion, property damage, severe personal injury or death.
- The unit must be permanently grounded. A grounding lug is provided. Failure to ground this unit can result in fire or electrical shock causing property damage, severe personal injury or death.
- Only electric heater kits supplied by this manufacturer as described in this publication have been designed, tested, and evaluated by a nationally recognized safety testing agency for use with this unit. Use of any other manufactured electric heaters installed within this unit may cause hazardous conditions resulting in property damage, fire, body injury or death.


WARNING: PROPOSITION 65

- This appliance contains fiberglass insulation. Respirable particles of fiberglass are known to the state of California to cause cancer.


CAUTION

Only use this unit in well-ventilated spaces and ensure that there are no obstructions that could impede the airflow into and out of the unit. Do not use this unit in the following locations:

- Locations with mineral oil.
- Locations with saline atmospheres, such as seaside locations.
- Locations with sulfurous atmospheres, such as near natural hot springs.
- Where high voltage electricity is present, such as in certain industrial locations.
- On vehicles or vessels, such as trucks or ferry boats.
- Where exposure to oily or very humid air may occur, such as kitchens.
- In proximity to sources of electromagnetic radiation, such as high-frequency transmitters or other high strength radiation devices.


CAUTION

A manufactured (mobile) home installation must conform with the Manufactured Home Construction and Safety Standard, Title 24 CFR, Part 3280, or when this Standard is not applicable, the Standard for Manufactured Home Installations (Manufactured Home Sites, Communities and Set-Ups), ANSI/NCS A225.1, and/or MH Series Mobile Homes, CAN/CSA Z240.

2 INSTALLATION

2.1 Inspection

As soon as unit is received, it should be inspected and noted for possible shipping damage during transportation. It is carrier's responsibility to cover the cost of shipping damage. Manufacturer or distributor will not accept the claims from dealer for any transportation damage.

2.2 Limitations

If components are to be added to a unit they must meet local codes, they are to be installed at the dealer's and / or the customer's expense.

Size of unit for proposed installation should be based on heat loss / heat gain calculations made in accordance with industry recognized procedures identified by the Air Conditioning Contractors of America.

2.3 Pre-Installation Checks

Before installation, carefully check the following:

1. Unit should be installed in accordance with national and local safety codes, including but not limit to ANSI/ NFPS No. 70 or Canadian Electrical Code Part 1, C22.1, local plumbing and wastewater codes and any other applicable codes.
2. For rooftop installation, be sure the structure has enough strength to support the weight of unit. Unit should be installed on roof curb and leveled.
3. For ground level installation, a level slab should be used.
4. Condenser airflow should not be restricted.
5. On applications when a roof curb is used, the unit must be positioned on the curb so the front of the unit is tight against the curb.



WARNING

Check the electric wire, water and gas pipeline layout inside the wall, floor and ceiling before installation. Do not implement drilling unless confirm safety with the user, especially for the hidden power wire. An electroprobe can be used to test whether a wire is passing by at the drilling location, to prevent physical injury or death caused by insulation broken cords.



WARNING

Check the power supply before installation. Ensure that the power supply must be reliably grounded following local, state and National Electrical Codes. If not, for example, if the ground wire is detected charged, installation is prohibited before it is rectified. Otherwise, there is a risk of fire and electric shock, causing physical injury or death.

2.4 Rigging & Handling

Exercise care when moving the unit. Do not remove any packaging until the unit is near the place of installation. Rig the unit by attaching chain or cable slings to the lifting holes provided in the base rails. Spreader bars, whose length exceeds the largest dimension across the unit, MUST be used across the top of the unit.



CAUTION

Before lifting, make sure the unit weight is distributed equally on the rigging cables so it will lift evenly.

Units may be moved or lifted with a forklift. Slotted openings in the base rails are provided for this purpose.



CAUTION

All panels must be secured in place when the unit is lifted. The condenser coils should be protected from rigging cable damage with plywood or other suitable material.

2.5 Unit Information & Dimensions




Figure 3.4a- Component Locations

*The above figure is for reference purposes only.

2 INSTALLATION

Unit Size: 24k, 30k, 36k




Figure 3.4b- Unit Dimensions

*The above figure is for reference purposes only.

Unit Size: 24k, 30k, 36k




Figure 3.4c- Back & Bottom Dimensions

*The above figure is for reference purposes only.

2 INSTALLATION

Unit Size: 42k, 48k, 60k




Figure 3.4d- 42k, 48k, & 60k Dimensions

*The above figure is for reference purposes only.

Unit Size: 42k, 48k, 60k




Figure 3.4e- 42k, 48k, & 60k Back & Bottom Dimensions

*The above figure is for reference purposes only.

2 INSTALLATION

2.6 Clearances

All units require certain clearance for proper operation and service. Refer to Table 2.6 for the clearances required for construction, servicing and proper unit operation.

Table 2.6- Unit Clearance

Direction	Distance (in.)	Direction	Distance (in.)
Top ¹	60	Right	30
Front	30	Left	24
Rear	18 ²	Bottom ³	0

Duct clearance: 1 inch clearance for all sides of air supply duct.

1. Units must be installed outdoors. Over hanging structure or shrubs should not obscure condenser air discharge outlet.
2. The minimum clearance without economizer/fresh air damper. For distance with economizer/fresh air damper, please refer to the installation instructions provided with the accessory.
3. Units may be installed on combustible floors made from wood or class A, B or C roof covering materials.

NOTE

For units applied with a roof curb, the minimum clearance may be reduced from 1 inch to 1/2 inch between combustible roof curb material and this supply air duct.

NOTE

A unit with electric heaters with an inlet or outlet duct that penetrates the building structure supporting the unit shall be provided with a mounting base of noncombustible material so designed that, after the unit is installed, there will be no open passages through the supporting structure that would permit flame or hot gases from a fire originating in the space below the supporting structure to travel to the space above that structure. If the unit is intended to be installed on a supporting structure of combustible material, the base shall be so designed that the required clearance will be maintained between the supporting structure and the unit, plenum, and attached duct. Spacers necessary to provide required clearances shall be attached to the unit mounting base, and shall extend not less than 76mm (3 in.) below the upper surface of the supporting structure, except that, in a unit designed for use only in a mobile home, the distance shall be not less than 19 mm (3/4 in.).

2.7 Ductwork

Ductwork should be sized and installed by the installing contractor in accordance with the Manual D from the Air Conditioning Contractors of America, and all national, state and local codes.

NOTE

On ductwork exposed to outside air space, use at least 2" of insulation and a vapor barrier. Flexible joint may be used to reduce noise.

A closed return duct system shall be used. This shall not preclude use of economizers or ventilation air intake. Flexible joints may be used in the supply and return duct work to minimize the transmission of noise.

! CAUTION

When fastening duct work to the side duct flanges on the unit, insert the screws through the duct flanges only. DO NOT insert the screws through the casing. Outdoor duct work must be insulated and waterproofed.

NOTE

Be sure to note supply and return openings. Refer to Fig. 2-3 and 2-5 for information concerning supply and return air duct openings.

2.8 Condensate Drain Pipe

Consult local codes for special requirements.

To provide extra protection from water damage, install an additional drain pan, provided by installer, under the entire unit with a separate drain line.

Manufacturer will not be responsible for any damages due to the failure to follow these requirements.

Install Drain Pipe

1. Use the provided female NPT threaded fitting for outside connection and make sure that drain holes are not blocked.
2. Insulation may be needed for drain line to prevent sweating.
3. Drain pan has two drain connections on each side to provide flexibility of connection and drainage. Make sure proper pitch and plugging if second connection is not used.
4. Use a sealing compound on male pipe threads. Install the condensate drain line (NPT) to spill into an open drain.
5. Ensure a trap is included in the condensate drain line.

2.9 Filters

Units are shipped without a filter or filter racks. It is the responsibility of the installer to secure a filter in the return air ductwork or install a filter/frame kit.


Filter must always be used and must be kept clean. Dirty filters may cause insufficient air delivery, decreasing unit efficiency and increasing operation costs and wear-and tear on the unit and controls.

Filters should be checked monthly; this is especially important since this unit is used for both heating and cooling.

3.1 Electrical Wiring Overview

Field wiring must comply with the National Electric Code (NEC) or Canadian Electrical Code (CEC) and any applicable local ordinance.

When installing power cables (in the middle) and signal cables (in the top) of the whole device, first remove the cable running apron, install the bushing, and finally install the power cables.



3.2 Power Wiring

1. Proper electrical power should be available at unit. Voltage tolerance should not be over 10% from rating voltage.
2. If any of the wire must be replaced, replacement wire must be the same type as shown in nameplate, wiring diagram and electrical data sheet.

3 ELECTRICAL WIRING

3. Install a branch circuit disconnect of adequate size to handle starting current, located within sight of, and readily accessible to the unit.
4. ELECTRIC HEATER - If the Electric Heater is installed, unit may be equipped with 30~60A. circuit breakers or fuse. These breaker(s) protect the internal wiring in the event of a short circuit and serve as a disconnect. Circuit breakers installed within the unit do not provide over-current protection of the supply wiring and therefore may be sized larger than the branch circuit protection.
 - Supply circuit power wiring must be 221 °F minimum copper conductors only.
 - See Electrical Data in this section for ampacity, wire size and circuit protector requirements. Supply circuit protective devices may be either fuses or "HACR" type circuit breakers.
 - 1-3/8" knockouts inside the cabinet are provided for connection of power wiring to electric heater.
 - Power wiring is connected to the power terminal block in unit electric cabinet.

See Electrical Heater Installation Instruction for details.

3.3 Grounding

! WARNING

The unit must be permanently grounded. Failure to do so can result in electrical shock causing personal injury or death.

- The unit must be electrically grounded in accordance with local codes or the national electric code.
- Grounding may be accomplished by attaching ground wire(s) to ground lug(s) provided in the unit wiring compartment.

3.4 Control Wiring

IMPORTANT: Class 2 low voltage control wiring should not be run in conduit with main power wiring and must be separated from power wiring, unless class 1 wire of proper voltage rating is used.

- Low voltage control wiring should be 18 AWG color-coded. For lengths longer than 50 ft, 16 AWG wire should be used.
- Two 7/8" holes can be used for control wires going into the unit, one on left side and one at the bottom.
- Make sure, after installation, separation of control wiring and power wiring has been maintained.

Thermostat should be mounted on an inside wall about 58" from floor and will not be affected by unconditioned air, sun and/or heat exposure. Follow the instruction carefully because there are many wiring requirements. **See Fig. 6-1 ~ 2, Table 6-1.**




Figure 3.4a- Typical Field Control Wiring Diagram

! CAUTION

Label all wire prior to disconnection when servicing controls. Wiring errors can cause improper and dangerous operation. Verify proper operation after servicing.




Figure 3.4b- Typical Field Power Wiring Diagram

Table 3.4a- 13.4 SEER2 W/Without Electric Heat

Size (Tons)	Volt	Compressors		OD Fan Motors	ID Fan Motors	Heater Circuit (without units)					
		RLA	LRA	FLA	FLA	Model	KW	Stages	Amps	MCA (Amps)	Max Fuse Breaker Size (Amps)
24k (2.0)	208/230 -1-60	9.2	43.0	1.0	2.5	None	-	-	None		
						MHK05PB	3.8-5	1	18.1/20.8	23/26	25/30
						MHK07PB	5.6-7.5	1	27.1/31.3	24k	24k
						MHK10PB	7.5/10	1	36.1/41.7	46/53	50/60
30k (2.5)	208/230 -1-60	10.2	58.0	43.0	43.0	None	-	-	None		
						MHK05PB	3.8/5	1	18.1/20.8	23/26	25/30
						MHK07PB	5.6/7.5	1	27.1/31.3	34/40	35/40
						MHK10PB	7.5/10	1	36.1/41.7	46/53	50/60
						MHK15PB	11.3/15	2	54.2/62.5	68/79	70/80
36k (3.0)	208/230 -1-60	13.0	75.0	43.0	43.0	None	-	-	None		
						MHK05PB	3.8/5	1	18.1/20.8	23/26	25/30
						MHK07PB	5.6/7.5	1	27.1/31.3	34/40	35/40
						MHK10PB	7.5/10	1	36.1/41.7	46/53	50/60
						MHK15PB	11.3/15	2	54.2/62.5	68/79	70/80

3 ELECTRICAL WIRING

Size (Tons)	Volt	Compressors		OD Fan Motors	ID Fan Motors	Heater Circuit (without units)					
		RLA	LRA	FLA	FLA	Model	KW	Stages	Amps	MCA (Amps)	Max Fuse Breaker Size (Amps)
42 (3.5)	208/230 -1-60	15.2	112.3	43.0	43.0	None	-	-	None		
						MHK05PB	3.8/5	1	18.1/20.8	23/26	25/30
						MHK07PB	5.6/7.5	1	27.1/31.3	34/40	35/40
						MHK10PB	7.5/10	1	36.1/41.7	46/53	50/60
						MHK15PB	11.3/15	2	54.2/62.5	68/79	70/80
						MHK20PB	15/20	2	72.3/83.4	91/105	100/110
48 (4.0)	208/230 -1-60	17.3	108.0	43.0	43.0	None	-	-	None		
						MHK05PB	3.8/5	1	18.1/20.8	23/26	25/30
						MHK07PB	5.6/7.5	1	27.1/31.3	34/40	35/40
						MHK10PB	7.5/10	1	36.1/41.7	46/53	50/60
						MHK15PB	11.3/15	2	54.2/62.5	68/79	70/80
						MHK20PB	15/20	2	72.3/83.4	91/105	100/110
60 (5.0)	208/230 -1-60	21.5	127.9	43.0	43.0	None	-	-	None		
						MHK05PB	3.8/5	1	18.1/20.8	23/26	25/30
						MHK07PB	5.6/7.5	1	27.1/31.3	34/40	35/40
						MHK10PB	7.5/10	1	36.1/41.7	46/53	50/60
						MHK15PB	11.3/15	2	54.2/62.5	68/79	70/80
						MHK20PB	15/20	2	72.3/83.4	91/105	100/110

024/030: Rotary compressor

036/042/048/060: Scroll compressor

1. Minimum Circuit Ampacity.
2. Maximum Over Current Protection per Standard UL 60335.
3. Fuse or HACR circuit breaker size installed at factory or field installed.

Table 3.4b- 13.4 SEER2 Physical Data

	Component	24	30	36	42	48	60
	Nominal Tonnage	2	2.5	3	3.5	4	5
ARI Cooling Performance	95°F Capacity Rating (Btu/h)	2280028	28200	34200	40500	46000	57000
	SEER2	13.4	13.4	13.4	13.4	13.4	13.4
	Nominal CFM	840	1060	1200	1450	1450	1700
	System Power (kW)	2.07	2.56	3.1	3.68	4.18	5.18
	Refrigerant Type	R410a	R410a	R410a	R410a	R410a	R410a
	Refrigerant Charge (lb-oz)	5-13	5-12	4-13	6-10	6-10	9-4
ARI Heating Performance	47°F Capacity Rating (Btu/h)	22400	28200	34200	40000	46000	57000
	System Power (kW)	1.88	2.36	2.86	3.35	3.85	4.77
	HSPF2 (BTU/Watts-hr.)	6.7	6.7	6.7	6.7	6.7	6.7
Dimensions (inches)	Length	52	52	52	58-1/2	58-1/2	58-1/2
	Width	37-3/4	37-3/4	37-3/4	42-1/16	42-1/16	42-1/16
	Height	24-13/16	24-13/16	24-13/16	33-1/16	33-1/16	33-1/16
	Operating Weight (lbs)	326	346	351	463	463	479
Compressors	Type	Rotary	Rotary	Scroll 1-spd	Scroll 1-spd	Scroll 1-spd	Scroll 1-spd
	Quantity	1	1	1	1	1	1
Condenser Coil Data	Face Area (Sq. ft)	9.8	9.8	9.44	15.54	15.54	15.3
	Rows	2	2	2.5	2	2	2.7
	Fins per inch	20	20	21	21	21	20
	Tube Diameter (inch)	9/32	9/32	3/16	3/16	3/16	9/32
	Tube Type	Innergroove Copper Tube					
	Circuitry Type	Interlaced	Interlaced	Interlaced	Interlaced	Interlaced	Interlaced
Evaporator Coil Data	Face Area (sq. ft.)	3.63	3.63	3.63	6.43	6.43	6.43
	Rows	4	4	4	4	4	4
	Fins per inch	17	17	17	17	17	17
	Tube Diameter	9/32	9/32	9/32	9/32	9/32	9/32
	Tube Type	Innergroove Aluminum Tube					
	Circuitry Type	Interlaced	Interlaced	Interlaced	Interlaced	Interlaced	Interlaced
	Refrigerant Control	Orifice	Orifice	Orifice	Orifice	Orifice	Orifice
Condenser Fan Data	Fan Diameter (in.)	22	22	22	23-5/8	23-5/8	23-5/8
	Type	Prop	Prop	Prop	Prop	Prop	Prop
	Drive Type	Direct/ECM	Direct/ECM	Direct/ECM	Direct/ECM	Direct/ECM	Direct/ECM
	No. speeds	10	10	10	10	10	10
	Number of motors	1	1	1	1	1	1
	Motor HP each	1/4	1/4	1/4	1/4	1/4	1/4
	RPM	200-800	200-980	200-980	200-980	200-980	200-980
	Nominal Total CFM	2300	2850	2500	3480	3480	3400
Direct Drive Evaporator Fan Data	Quantity	1	1	1	1	1	1
	Fan Size (in.)	10x9	10x9	10x9	11x10-5/8	11x10-5/8	11x10-5/8
	Type	Centrifugal	Centrifugal	Centrifugal	Centrifugal	Centrifugal	Centrifugal
	No. Speeds	1	1	1	1	1	1
	Motor HP each	1/4	1/2	1/2	3/4	3/4	3/4
	RPM	1050	1050	1050	1050	1050	1050
	Motor Frame Size	48	48	48	48	48	48
Electrical Data	Voltage-Phase-Hz	208/230-1-60	208/230-1-60	208/230-1-60	208/230-1-60	208/230-1-60	208/230-1-60
	Min/Max Volts	188/253	188/253	188/253	188/253	188/253	188/253
Return-Air Filters	Throwaway (in.) (mm)	24x30x1	24x30x1	24x30x1	24x36x1	24x36x1	24x36x1
		610x762x25	610x762x25	610x762x25	610x914x25	610x914x25	610x914x25

4 AIR FLOW PERFORMANCE

4.1 Duct Application (208V)

Airflow performance data is based on cooling performance with a coil and no filter in place. Use this performance table for appropriate unit size, external static applied to unit and allow operation within the minimum and maximum limits shown in table below for both cooling and electric heat operation.

Table 4.1a Duct Application (208V)

Model	Motor Speed		External Static Pressure-Inches W.C. [kPa]								
			0[0]	0.1[.02]	0.2[.05]	.3[.07]	0.4[.10]	0.5[.12]	0.6[.15]	0.7[.17]	0.8[.20]
24	Low-Tap (1)	SCFM	787	744	691	643	/	/	/	/	/
		Watts	187	185	182	152	/	/	/	/	/
		Amps	0.98	0.77	0.75	0.73	/	/	/	/	/
	Mid-Tap (2) (Factory)	SCFM	/	/	/	882	828	751	698	/	/
		Watts	/	/	/	269	262	253	246	/	/
		Amps	/	/	/	1.37	1.34	1.31	1.27	/	/
	High-Tap (3)	SCFM	/	/	/	/	/	964	896	759	621
		Watts	/	/	/	/	/	360	330	307	276
		Amps	/	/	/	/	/	1.78	1.71	1.64	1.57
30	Low-Tap (1)	SCFM	956	908	860	815	771	/	/	/	/
		Watts	1.2	1.27	1.35	1.44	1.52	/	/	/	/
		Amps	114	122	131	141	151	/	/	/	/
	Mid-Tap (2)	SCFM	1082	1039	996	958	917	881	831	780	/
		Watts	1.54	1.63	1.73	1.82	1.92	2.01	2.12	2.21	/
		Amps	153	164	175	186	119	209	221	231	/
	High-Tap (3) (Factory)	SCFM	/	/	/	1102	1066	1031	998	964	916
		Watts	/	/	/	2.34	2.46	2.56	2.66	2.76	2.88
		Amps	/	/	/	248	261	274	286	297	312
36	Low-Tap (2)	SCFM	1082	1039	996	958	917	/	/	/	/
		Watts	1.54	1.63	1.73	1.82	1.92	/	/	/	/
		Amps	153	164	175	186	119	/	/	/	/
	Mid-Tap (3)	SCFM	1219	1179	1140	1102	1066	1031	998	964	916
		Watts	2.03	2.14	2.24	2.34	2.46	2.56	2.66	2.76	2.88
		Amps	211	223	235	248	261	274	286	297	312
	High-Tap (4) Factory	SCFM	1350	1321	1283	1248	1214	1181	1147	1115	1084
		Watts	2.63	2.75	2.86	2.97	3.09	3.2	3.32	3.43	3.53
		Amps	283	297	309	322	337	351	365	378	391
42	Low-Tap (1) (Factory)	SCFM	1545	1507	1463	1418	1366	1307	1239	1144	/
		Watts	487	479	469	458	447	433	418	400	/
		Amps	2.58	2.55	2.52	2.49	2.46	2.42	2.38	2.33	/
	Mid-Tap (2)	SCFM	/	/	/	/	1551	1488	1414	1318	1200
		Watts	/	/	/	/	728	712	693	672	644
		Amps	/	/	/	/	4.1	4.05	3.99	3.92	3.84
	High-Tap (3)	SCFM	/	/	/	/	/	/	1570	1499	1380
		Watts	/	/	/	/	/	/	812	787	759
		Amps	/	/	/	/	/	/	4.57	4.49	4.4

4 AIR FLOW PERFORMANCE

Model	Motor Speed		External Static Pressure-Inches W.C. [kPa]								
			0[0]	0.1[.02]	0.2[.05]	.3[.07]	0.4[.10]	0.5[.12]	0.6[.15]	0.7[.17]	0.8[.20]
48	Low-Tap (1) (Factory)	SCFM	1545	1507	1463	1418	1366	1307	1239	/	/
		Watts	487	479	469	458	447	433	418	/	/
		Amps	2.58	2.55	2.52	2.49	2.46	2.42	2.38	/	/
	Mid-Tap (2)	SCFM	1740	1699	1654	1606	1551	1488	1414	1318	1200
		Watts	783	768	756	742	728	712	693	672	644
		Amps	4.27	4.22	4.18	4.14	4.1	4.05	3.99	3.92	3.84
	High-Tap (3)	SCFM	/	/	/	1800	1740	1671	1595	1499	1380
		Watts	/	/	/	874	854	833	812	787	759
		Amps	/	/	/	4.76	4.7	4.63	4.57	4.49	4.4
60	Low-Tap (3) (Factory)	SCFM	1777	1728	1680	1635	1592	1549	/	/	/
		Watts	2.8	2.9	3	3.1	3.2	3.3	/	/	/
		Amps	323	338	352	365	378	391	/	/	/
	Mid-Tap (4) (Factory)	SCFM	1937	1889	1842	1792	1758	1720	1678	1636	1593
		Watts	3.5	3.6	3.7	3.8	3.9	4	4.1	4.2	4.3
		Amps	412	428	444	457	471	486	499	513	527
	High-Tap (5)	SCFM	2235	2191	2144	2091	2050	2010	1971	1936	1892
		Watts	4.5	5.1	5.3	5.4	5.5	5.6	5.7	5.8	5.8
		Amps	623	642	660	673	689	704	719	734	744

Table 4.1b Duct Application (230V)

Model	Motor Speed		External Static Pressure-Inches W.C. [kPa]								
			0[0]	0.1[.02]	0.2[.05]	.3[.07]	0.4[.10]	0.5[.12]	0.6[.15]	0.7[.17]	0.8[.20]
24	Low-Tap (1)	SCFM	885	841	795	743	/	/	/	/	/
		Watts	227	224	221	216	/	/	/	/	/
		Amps	2.07	2.07	2.06	2.05	/	/	/	/	/
	Mid-Tap (2) (Factory)	SCFM	/	/	/	988	957	882	767	/	/
		Watts	/	/	/	339	323	307	291	/	/
		Amps	/	/	/	2.31	2.28	2.26	2.24	/	/
	High-Tap (3)	SCFM	/	/	/	/	/	996	967	928	896
		Watts	/	/	/	/	/	412	392	379	361
		Amps	/	/	/	/	/	2.65	2.57	2.52	2.46
30	Low-Tap (1)	SCFM	956	908	860	815	771	/	/	/	/
		Watts	1.2	1.27	1.35	1.44	1.52	/	/	/	/
		Amps	114	122	131	141	151	/	/	/	/
	Mid-Tap (2)	SCFM	1082	1039	996	958	917	881	831	780	/
		Watts	1.54	1.63	1.73	1.82	1.92	2.01	2.12	2.21	/
		Amps	153	164	175	186	119	209	221	231	/
	High-Tap (3) (Factory)	SCFM	/	/	/	1102	1066	1031	998	964	916
		Watts	/	/	/	2.34	2.46	2.56	2.66	2.76	2.88
		Amps	/	/	/	248	261	274	286	297	312

4 AIR FLOW PERFORMANCE

Model	Motor Speed		External Static Pressure-Inches W.C. [kPa]								
			0[0]	0.1[.02]	0.2[.05]	.3[.07]	0.4[.10]	0.5[.12]	0.6[.15]	0.7[.17]	0.8[.20]
36	Low-Tap (2)	SCFM	1082	1039	996	958	917	/	/	/	/
		Watts	1.54	1.63	1.73	1.82	1.92	/	/	/	/
		Amps	153	164	175	186	119	/	/	/	/
	Mid-Tap (3)	SCFM	1219	1179	1140	1102	1066	1031	998	964	916
		Watts	2.03	2.14	2.24	2.34	2.46	2.56	2.66	2.76	2.88
		Amps	211	223	235	248	261	274	286	297	312
	High-Tap (4) (Factory)	SCFM	1350	1321	1283	1248	1214	1181	1147	1115	1084
		Watts	2.63	2.75	2.86	2.97	3.09	3.2	3.32	3.43	3.53
		Amps	283	297	309	322	337	351	365	378	391
42	Low-Tap (1) (Factory)	SCFM	/	/	/	/	1554	1495	1429	1340	1230
		Watts	/	/	/	/	527	510	3046	465	432
		Amps	/	/	/	/	2.29	2.22	13.24	2.02	1.88
	Mid-Tap (2)	SCFM	/	/	/	/	/	/	/	1503	1384
		Watts	/	/	/	/	/	/	/	566	533
		Amps	/	/	/	/	/	/	/	2.46	2.32
	High-Tap (3)	SCFM	/	/	/	/	/	/	/	/	1548
		Watts	/	/	/	/	/	/	/	/	662
		Amps	/	/	/	/	/	/	/	/	2.88
48	Low-Tap (1) (Factory)	SCFM	1735	1701	1654	1608	1554	1495	1429	1340	/
		Watts	579	573	561	545	527	510	469	465	/
		Amps	2.52	2.49	2.44	2.37	2.29	2.22	2.15	2.02	/
	Mid-Tap (2)	SCFM	/	/	/	1790	1730	1665	1591	1503	1384
		Watts	/	/	/	658	642	614	592	566	533
		Amps	/	/	/	2.86	2.79	2.67	2.57	2.46	2.32
	High-Tap (3)	SCFM	/	/	/	/	/	/	1761	1666	1548
		Watts	/	/	/	/	/	/	732	704	662
		Amps	/	/	/	/	/	/	3.18	3.06	2.88
60	Low-Tap (3) (Factory)	SCFM	1777	1728	1680	1635	1592	1549	/	/	/
		Watts	2.8	2.9	3	3.1	3.2	3.3	/	/	/
		Amps	323	338	352	365	378	391	/	/	/
	Mid-Tap (4) (Factory)	SCFM	1937	1889	1842	1792	1758	1720	1678	1636	1593
		Watts	3.5	3.6	3.7	3.8	3.9	4	4.1	4.2	4.3
		Amps	412	428	444	457	471	486	499	513	527
	High-Tap (5)	SCFM	2235	2191	2144	2091	2050	2010	1971	1936	1892
		Watts	4.5	5.1	5.3	5.4	5.5	5.6	5.7	5.8	5.8
		Amps	623	642	660	673	689	704	719	734	744

* The above airflow data for reference only.

* In any situation , the airflow of the unit should be in the range of 80% to 130% of 400CFM/Ton.

- The air distribution system has the greatest effect on airflow. The duct system is totally controlled by the contractor. For this reason, the contractor should use only industry-recognized procedures.
- Heat pump systems require a specified airflow. Each ton of cooling requires between 300 and 450 cubic feet of air per minute (CFM), or 400 CFM nominally.
- Duct design and construction should be carefully done. System performance can be lowered dramatically due to poor duct design.
- The installers should balance the air distribution system to ensure proper quiet airflow to all rooms in the home. This ensures a comfortable living space.

4 AIR FLOW PERFORMANCE

- Air supply diffusers must be selected and located carefully. They must be sized and positioned to deliver treated air along the perimeter of the space. If they are too small for their intended airflow, they become noisy. If they are not located properly, they cause drafts. Return air grilles must be properly sized to carry air back to the blower. If they are too small, they also cause noise.
- An air velocity meter or airflow hood can give a reading of system CFM.
- During installation, installer should select the air speed according to the actual setting static pressure. Please refer to the Table 7.1a and 7.1b.

**Table 4.1c - Electric Heat Pressure Drop Tables (in.W.C.)
Small Cabinet: 24K, 30K, 36K**

Static	Standard CFM (SCFM)					
	900	1000	1100	1200	1300	1400
5kW	0.05	0.05	0.05	0.05	0.05	0.1
7.5kW	0.05	0.05	0.05	0.05	0.05	0.1
10kW	0.05	0.05	0.05	0.05	0.05	0.1
15kW	/	/	0.1	0.1	0.1	0.1

Large Cabinet: 42K, 48K, 60K

Static	Standard CFM (SCFM)							
	1500	1600	1700	1800	1900	2000	2100	2200
5kW	0.1	0.1	0.1	0.1	0.15	0.15	0.15	0.15
7.5kW	0.1	0.1	0.1	0.1	0.15	0.15	0.15	0.15
10kW	0.1	0.1	0.15	0.15	0.15	0.15	0.15	0.15
15kW	/	/	0.2	0.2	0.2	0.2	0.2	0.2
20kW	/	/	0.2	0.2	0.2	0.2	0.2	0.25

Table 4.1d - Refrigerant Charge for 24k H/P System

24k Cooling Mode	Cooling Charge Chart													
	Outdoor Ambient Temperature (oF)													
	55	60	65	70	75	80	85	90	95	100	105	110	115	
High Pressure Service Port (psig)														
Low Pressure Service Port (psig)	165			303	316	328	350	370	400	426	446	465	487	508
	161			300	313	325	346	366	394	421	440	459	481	503
	157			297	310	322	342	362	389	415	434	453	476	499
	153		282	294	307	319	339	358	384	410	428	446	471	496
	149		279	291	304	316	335	353	374	399	419	443	468	493
	145		275	287	300	312	331	349	370	393	416	440	465	490
	141	256	272	284	297	309	328	346	368	389	413	437	462	486
	137	251	268	280	293	305	324	343	365	386	410	434	459	483
	133	246	264	276	289	301	321	340	361	382	406	430	455	479
	129	241	260	272	285	297	317	336	357	378	403	427	451	475
	125	236	256	268	281	293	313	332	353	375	399	423	447	471
	121	231	252	264	277	289	309	328	349	370	395	420	444	467
	117	226	248	260	273	285	305	324	345	366	392	417	440	463
	113	221	244	256	269	281	301	320	341	362	388	414	437	459
109	216	240	252	265	277	297	316	337	358	385	411	433	455	
105	211	236	249	261	273	293	312	333	354	381	408	429	450	

4 AIR FLOW PERFORMANCE

Table 4.1e - Refrigerant Charge for 24k H/P System

24k Heating Mode		Heating Charge Chart											
		Indoor Dry Bulb Temperature (oF)											
		60	62	64	66	68	70	72	74	76	78	80	82
		High Pressure Service Port (psig)											
Low Pressure Service Port (psig)	135	361	369	377	385	393	401	409	417	425	433	441	448
	128	346	354	361	369	377	385	393	400	408	416	424	431
	121	331	338	346	353	361	369	375	384	391	399	407	414
	114	315	323	330	338	345	352	360	367	375	382	389	396
	107	300	307	315	322	329	336	343	351	358	365	372	379
	100	285	292	299	306	313	320	327	334	341	348	355	362
	93	276	283	289	296	303	310	317	324	331	338	345	352
	86	267	273	280	286	293	300	307	314	321	328	335	342
	79	257	264	270	277	283	289	296	303	310	317	324	331
	72	248	254	261	267	273	279	286	293	300	307	314	321
	65	239	245	251	257	253	269	276	283	290	297	304	311
	58					256	262	269	276	283	290	297	304
	51						255	262	269	276	283	290	297
	44							255	262	269	276	283	290
	37								255	262	269	276	283
30													

Table 4.1f - Refrigerant Charge for 30k H/P System

30k Cooling Mode		Cooling Charge Chart												
		Outdoor Ambient Temperature (oF)												
		55	60	65	70	75	80	85	90	95	100	105	110	115
		High Pressure Service Port (psig)												
Low Pressure Service Port (psig)	165			281	303	324	346	365	383	402	425	449	472	495
	161			279	301	322	344	363	381	400	423	447	470	493
	157			277	299	320	342	361	379	398	421	445	468	491
	153		253	275	297	318	240	359	377	396	419	443	466	489
	149		251	273	295	316	338	357	375	394	417	441	464	487
	145		249	271	293	314	336	355	373	392	415	439	462	485
	141	226	247	269	291	312	334	353	371	390	413	437	460	483
	137	224	245	267	289	310	332	351	369	388	411	435	458	481
	133	222	243	265	287	308	330	349	367	386	409	433	456	479
	129	220	241	263	285	306	328	347	365	384	407	431	454	477
	125	218	239	261	283	304	326	345	363	382	405	429	452	475
	121	216	237	259	281	302	324	343	361	380	403	427	450	473
	117	214	235	257	279	300	322	341	359	378	401	425	448	471
	113	212	233	255	277	298	320	339	357	376	399	423	446	469
	109	210	231	253	275	296	318	337	355	374	397	421	444	467
105	208	229	251	273	294	316	335	353	372	395	419	442	465	

Table 4.1g - Refrigerant Charge for 30k H/P System

30k Heating Mode		Heating Charge Chart											
		Indoor Dry Bulb Temperature (oF)											
		60	62	64	66	68	70	72	74	76	78	80	82
		High Pressure Service Port (psig)											
Low Pressure Service Port (psig)	135	361	369	377	385	393	401	409	417	425	433	441	448
	128	346	354	361	369	377	385	393	400	408	416	424	431
	121	331	338	346	353	361	369	376	384	391	399	407	414
	114	315	323	330	338	345	352	360	367	375	382	389	396
	107	300	307	315	322	329	336	343	351	358	365	372	379
	100	285	292	299	306	313	320	327	334	341	348	355	362
	93	275	282	289	296	302	309	316	323	330	337	344	351
	86	265	272	279	285	292	298	305	312	319	326	333	340
	79	256	262	268	275	281	288	295	302	309	316	323	330
	72	246	252	258	264	271	277	284	291	298	305	312	319
	65	236	242	248	254	260	266	273	280	287	294	301	308
	58					253	259	266	273	280	287	294	301
	51						252	259	266	273	280	287	294
	44							252	259	266	273	280	287
37								252	259	266	273	280	
30													

Table 4.1h - Refrigerant Charge for 36k H/P System

36k Cooling Mode		Cooling Charge Chart												
		Outdoor Ambient Temperature (oF)												
		55	60	65	70	75	80	85	90	95	100	105	110	115
		High Pressure Service Port (psig)												
Low Pressure Service Port (psig)	165			313	328	343	357	370	391	423	448	472	495	521
	161			309	324	339	353	366	387	419	444	468	491	516
	157			305	320	335	349	362	383	415	439	463	486	512
	153		286	301	316	331	345	358	379	411	435	459	482	508
	149		282	297	312	327	341	354	375	407	431	455	478	503
	145		278	293	308	323	337	350	372	404	428	451	474	500
	141	253	274	289	304	319	333	346	368	401	424	447	470	495
	137	246	268	283	298	313	328	342	363	397	421	444	471	501
	133	241	264	279	294	309	324	339	360	394	418	441	463	487
	129	236	260	275	290	305	321	337	358	391	415	438	461	486
	125	231	256	271	286	301	317	333	355	389	412	435	457	482
	121	226	252	267	282	297	313	329	351	386	409	432	454	478
	117	221	248	263	278	293	309	325	348	383	406	429	450	474
	113	216	244	259	274	289	305	321	344	380	403	426	447	470
	109	211	240	255	270	285	301	317	341	377	400	423	443	466
	105	206	236	251	266	281	297	313	337	374	397	420	440	462

4 AIR FLOW PERFORMANCE

Table 4.1i - Refrigerant Charge for 36k H/P System

36k Heating Mode		Heating Charge Chart											
		Indoor Dry Bulb Temperature (oF)											
		60	62	64	66	68	70	72	74	76	78	80	82
		High Pressure Service Port (psig)											
Low Pressure Service Port (psig)	135	344	352	360	368	376	384	392	400	408	416	424	431
	128	335	343	350	358	366	374	382	389	397	405	413	420
	121	326	333	341	348	356	364	371	379	386	394	402	409
	114	316	324	331	339	346	353	361	368	376	383	390	397
	107	307	314	322	329	336	343	350	358	365	372	379	386
	100	298	305	312	319	326	333	340	347	354	361	368	375
	93	287	293	300	307	314	321	328	335	342	349	356	363
	86	275	282	288	295	302	308	315	322	329	336	343	350
	79	264	270	277	283	289	296	303	310	317	324	331	338
	72	252	259	265	271	277	283	290	297	304	311	318	325
	65	241	247	253	259	265	271	278	285	292	299	306	313
	58					258	264	271	278	285	292	299	306
	51						257	264	271	278	285	292	299
	44							257	264	271	278	285	292
37								257	264	271	278	285	
30													

Table 4.1j - Refrigerant Charge for 42k H/P System

42k Cooling Mode		Cooling Charge Chart												
		Outdoor Ambient Temperature (oF)												
		55	60	65	70	75	80	85	90	95	100	105	110	115
		High Pressure Service Port (psig)												
Low Pressure Service Port (psig)	165			267	288	310	331	347	364	380	405	430	454	479
	161			264	286	308	329	345	362	378	403	428	452	477
	157			263	284	306	327	343	360	376	401	426	450	475
	153		240	261	282	304	325	341	358	374	399	424	448	473
	149		238	259	280	302	323	339	356	372	397	422	446	471
	145		236	257	278	300	321	337	354	370	395	420	444	469
	141	212	234	255	276	298	319	335	352	368	393	418	442	467
	137	210	232	253	274	296	317	333	350	366	391	416	440	465
	133	208	230	251	272	294	315	331	348	364	389	414	438	463
	129	206	228	249	270	292	313	329	346	362	387	412	436	461
	125	204	226	247	268	290	311	327	344	360	385	410	434	459
	121	202	224	245	266	288	309	325	342	358	383	408	432	457
	117	200	222	243	264	286	307	323	340	356	381	406	430	455
	113	198	220	241	262	284	305	321	338	354	379	404	428	453
	109	196	218	239	260	282	303	319	336	352	377	402	426	451
	105	194	216	237	258	280	301	317	334	350	375	400	424	449

Table 4.1k - Refrigerant Charge for 42k H/P System

42k Heating Mode		Heating Charge Chart											
		Indoor Dry Bulb Temperature (oF)											
		60	62	64	66	68	70	72	74	76	78	80	82
		High Pressure Service Port (psig)											
Low Pressure Service Port (psig)	135	388	396	404	412	420	428	436	444	452	460	468	475
	128	364	372	380	387	395	403	411	419	426	434	442	449
	121	340	348	355	363	370	378	386	393	401	408	416	423
	114	316	323	331	338	346	353	360	368	375	383	390	397
	107	292	299	306	314	321	328	335	342	350	357	364	371
	100	268	275	282	289	296	303	310	317	324	331	338	345
	93	261	268	275	281	288	295	302	309	316	323	330	337
	86	254	261	267	274	280	287	294	301	308	315	322	329
	79	247	253	260	266	273	279	286	293	300	307	314	321
	72	240	246	252	259	265	271	278	285	292	299	306	313
	65	233	239	245	251	257	263	270	277	284	291	298	305
	58					250	256	263	270	277	284	291	298
	51						249	256	263	270	277	284	291
	44							249	256	263	270	277	284
37								249	256	263	270	277	
30													

Table 4.1l - Refrigerant Charge for 48k H/P System

48k Cooling Mode		Cooling Charge Chart												
		Outdoor Ambient Temperature (oF)												
		55	60	65	70	75	80	85	90	95	100	105	110	115
		High Pressure Service Port (psig)												
Low Pressure Service Port (psig)	165			277	298	320	341	359	378	396	421	445	470	494
	161			275	296	318	339	357	376	394	419	443	468	492
	157			273	294	316	337	355	375	392	417	441	466	490
	153		250	271	292	314	335	353	372	390	415	439	464	488
	149		248	269	290	312	333	351	370	388	413	437	462	486
	145		246	267	288	310	331	349	368	386	411	435	460	484
	141	222	244	265	286	308	329	347	366	384	409	433	458	482
	137	220	242	263	284	306	327	345	364	382	407	431	456	480
	133	218	240	261	282	304	325	343	362	380	405	429	454	478
	129	216	238	259	280	302	323	341	360	378	403	427	452	476
	125	214	236	257	278	300	321	339	358	376	401	425	450	474
	121	212	234	255	276	298	319	337	356	374	399	423	448	472
	117	210	232	253	274	296	317	335	354	372	397	421	446	470
	113	208	230	251	272	294	315	333	352	370	395	419	444	468
	109	206	228	249	270	292	313	331	350	368	393	417	442	466
	105	204	226	247	268	290	311	329	348	366	391	415	440	464

4 AIR FLOW PERFORMANCE

Table 4.1m - Refrigerant Charge for 42k H/P System

48k Heating Mode		Heating Charge Chart															
		Indoor Dry Bulb Temperature (oF)															
		60	62	64	66	68	70	72	74	76	78	80	82				
Low Pressure Service Port (psig)		High Pressure Service Port (psig)															
		135	128	121	114	107	100	93	86	79	72	65	58	51	44	37	30
	135	418	426	434	442	450	458	466	474	482	490	498	505				
	128	392	400	408	412	423	431	439	447	454	462	470	477				
	121	366	374	381	389	396	404	412	419	427	434	442	449				
	114	340	347	355	362	370	377	384	392	399	407	414	421				
	107	314	321	328	336	343	350	357	364	372	379	386	393				
	100	288	295	302	309	316	323	330	337	344	351	358	365				
	93	279	285	292	299	306	313	320	327	334	341	348	355				
	86	269	276	282	289	296	302	309	316	323	330	337	344				
	79	260	266	273	279	285	292	299	306	313	320	327	334				
	72	250	257	263	269	275	281	288	295	302	309	316	323				
	65	241	247	253	259	265	271	278	285	292	299	306	313				
	58					258	264	271	278	285	292	299	306				
	51						257	264	271	278	285	292	299				
	44							257	264	271	278	285	292				
	37								257	264	271	278	285				
	30																

Table 4.16n - Refrigerant Charge for 60k H/P System

60k Cooling Mode		Cooling Charge Chart															
		Outdoor Ambient Temperature (oF)															
		55	60	65	70	75	80	85	90	95	100	105	110	115			
Low Pressure Service Port (psig)		High Pressure Service Port (psig)															
		165	161	157	153	149	145	141	137	133	129	125	121	117	113	109	105
	165			297	318	339	360	379	399	418	442	466	490	514			
	161			295	316	337	358	377	397	416	440	464	488	512			
	157			293	314	335	356	375	395	414	438	462	486	510			
	153		270	291	312	333	354	373	393	412	436	460	484	508			
	149		268	289	310	331	352	371	391	410	434	458	482	506			
	145		266	287	308	329	350	369	389	408	432	456	480	504			
	141	243	264	285	306	327	348	367	387	406	430	454	478	502			
	137	241	262	283	304	325	346	365	385	404	428	452	476	500			
	133	239	260	281	302	323	344	363	383	402	426	450	474	498			
	129	237	258	279	300	321	342	361	381	400	424	448	472	496			
	125	235	256	277	298	319	340	359	379	398	422	446	470	494			
	121	233	254	275	296	317	338	357	377	396	420	444	468	492			
	117	231	252	273	294	315	336	355	375	394	418	442	466	490			
	113	229	250	271	292	313	334	353	373	392	416	440	464	488			
	109	227	248	269	290	311	332	351	371	390	414	438	462	486			
	105	225	246	267	288	309	330	349	369	388	412	436	460	484			

Table 4.1o - Refrigerant Charge for 60k H/P System

60k Heating Mode		Heating Charge Chart															
		Indoor Dry Bulb Temperature (oF)															
		60	62	64	66	68	70	72	74	76	78	80	82				
Low Pressure Service Port (psig)		High Pressure Service Port (psig)															
		135	128	121	114	107	100	93	86	79	72	65	58	51	44	37	30
	135	431	439	447	455	463	471	479	487	495	503	511	518				
	128	405	413	421	429	436	444	452	460	468	475	483	490				
	121	379	387	395	402	410	417	425	433	440	448	455	462				
	114	354	361	368	376	383	391	398	405	413	420	428	435				
	107	328	335	342	349	357	364	371	378	385	393	400	407				
	100	302	309	316	323	330	337	344	351	358	365	372	379				
	93	291	298	305	312	318	325	332	339	346	353	360	367				
	86	280	287	294	300	307	313	320	327	334	341	348	355				
	79	270	276	282	289	295	302	309	316	323	330	337	344				
	72	259	265	271	277	284	290	297	304	311	318	325	332				
	65	248	254	260	266	272	278	285	292	299	306	313	320				
	58					265	271	278	285	292	299	306	313				
	51						264	271	278	285	292	299	306				
	44							264	271	278	285	292	299				
	37								264	271	278	285	292				
	30																

5.1 Compressor Crankcase Heater

Refrigerant migration during the off cycle can result in a noisy start up. Add a crankcase heater to minimize refrigeration migration, and to help eliminate any start up noise or bearing “wash out”.

All heaters are located on the lower half of the compressor shell. Its purpose is to drive refrigerant from the compressor shell during long off cycles, thus preventing damage to the compressor during start-up.

At initial start-up or after extended shutdown periods, make sure the heater is energized for at least 12 hours before the compressor is started. (Disconnect switch on and wall thermostat off.)

The crankcase heater will start up or shut down according to the following logic:

- The crankcase heater will start up when the compressor is off and $T4 < 41^\circ\text{F}$.
- The crankcase heater will shut down when $T4 \geq 45^\circ\text{F}$
- In any condition, the crankcase heater will shut down when the compressor is on.

5.2 Protection

Protection for HP System

If sensors (T3 & T4) become open-circuit or short-circuit, the compressor, outdoor fan motor, and reversing valve circuit will shut down.

Discharge temperature protection:

If discharge temp. is $> 239^\circ\text{F}$, the compressor will shut down, If discharge temp. is $< 167^\circ\text{F}$, the compressor will resume operation.

High pressure protection:

If high pressure is $> 609\text{PSIG}$, the compressor and the outdoor fan motor will stop running. If high pressure is $< 464\text{PSIG}$, the compressor and the outdoor fan motor will resume running (3 minute delay necessary).

5 SYSTEM OPERATION

Low pressure protection:

When low pressure is $< 21\text{PSIG}$, the compressor and the outdoor fan motor will stop running. When low pressure is $> 44\text{PSIG}$, the compressor and the outdoor fan motor will resume running (3 minutes delay necessary).

In stand-by status, if low pressure protection was detected, the compressor will not start. If protection cycles occur four times within 30 minutes, the compressor and outdoor fan will shut down. In this condition, the system needs to power on once more in order to keep on working.

T4 function:

When T4 is $< 5\text{ }^\circ\text{F}$, the compressor will stop. If the electrical heater kit is installed in the indoor unit, the outdoor unit will send the operation signal to the indoor unit.

When T4 is $> 10.4\text{ }^\circ\text{F}$, the compressor will restart.

5.3 Defrost Mode Introduction

Manual defrost mode

To manually cycle the defrost mode, set switch SW3-1 to the "ON" position (See Fig 8-1). The system will engage a defrost cycle, and automatically exit defrost mode once the Shut-down conditions of defrost mode described below are met.

Caution: Once the manual defrost mode is finished, please set switch SW3-1 back to "OFF".

Start-Up Conditions of Defrost Mode

When SW3-1 switch is set to "ON" (See Fig 8-1), the system will perform a defrost cycle in any of the following conditions:

1. If the compressor is operating and T3 is $< 32\text{ }^\circ\text{F}$, the system will perform a defrost cycle every 30 minutes of operation.
2. If the compressor is operating and T4 is $< 37.4\text{ }^\circ\text{F}$, the system will perform a defrost cycle every 30 minutes of operation.
3. When T3 is $< 28.4\text{ }^\circ\text{F}$ and the compressor is operating for the first time after being connected power, the system will perform a defrost after 15 minutes for the first time.
4. When T3 is $< 28.4\text{ }^\circ\text{F}$ and the system has been in standby for two hours, the system will perform a defrost after 15 minutes for the first time.




Figure 5.3- SW3 Switch Location in the PCB Board
(For reference only)

	SW3-1	ON	Manual Defrost
		OFF	Automatic Defrost
	SW3-2	ON	Reserved
		OFF	Normal Defrost
	SW3-3	ON	Defrosting Cycle: 30 min.
		OFF	Defrosting Cycle: 60 min.

When SW3-1 switch is set to "OFF", the system will perform a defrost cycle in any of the following conditions:

1. If the compressor is operating and T3 is < 32 °F, the system will perform a defrost cycle every 60 minutes of operation.
2. If the compressor is operating and T4 is < 37.4 °F, the system will perform a defrost cycle every 60 minutes of operation.
3. When T3 is < 28.4 °F and the compressor is operating for the first time after being connected power, the system will perform a defrost after 15 minutes for the first time.
4. When T3 is < 28.4 °F and the system has been in standby for two hours, the system will perform a defrost after 15 minutes for the first time.

Shut-down conditions of defrost mode:

No matter what defrost mode is selected, the defrost cycle will end in any of the following conditions:

1. The defrost cycle has been running for 10 minutes;
2. T3 is ≥ 64.4°F for more than 60s;
3. The compressor stops operating.

5.4 Thermostat Signals

Table 5.4a - Thermostat Signals

Signal	State	Board Function
G	ON	Blower instant ON
	OFF	Blower 90 sec. OFF
G & W1	ON	Blower instant ON Heater Bank 1 elec. instant ON
	OFF	Heater Bank 1 elec. instant OFF Blower 90 sec. delay OFF
G & W & W2	ON	Blower Instant ON Heater 1 instant ON Heater 2 instant ON
	OFF	Blower 90 sec. delay OFF Heater 1 instant OFF Heater 2 instant OFF
G & Y	ON	Blower instant ON Compressor and outdoor fan instant ON
	OFF	Compressor and outdoor fan instant OFF Blower fan delay 90 sec. OFF
G & B & Y	ON	4-way valve instant ON Blower instant ON Compressor and outdoor fan instant ON
	OFF	Compressor and outdoor fan instant OFF Blower fan delay 90 sec. OFF 4-way valve instant OFF

Signal	State	Board Function
G & B & Y & W1	ON	4-way valve instant ON Blower instant ON Compressor and outdoor fan instant ON Heater 1 instant ON
	OFF	4-way valve instant OFF Blower fan delay 90 sec. OFF Compressor and outdoor fan instant OFF Heater 1 instant OFF
G & B & Y & W1 & W2	ON	4-way valve instant ON Blower instant ON Compressor and outdoor fan instant ON Heater 1 instant ON Heater 2 instant ON
	OFF	4-way valve instant OFF Blower fan delay 90 sec. OFF Compressor and outdoor fan instant OFF Heater 1 instant OFF Heater 2 instant OFF

Table 5.4b - Thermostat Wire Colors

Thermostat Wire Color	Function
Red	Power Wire
Black	Power Wire
White	Heater Signal 1
Green	Blower Fan Signal
Yellow	Compressor Signal
Blue	Reversing Valve Signal
White/Black	Heater Signal 2

6 OPERATION CHECK-UP

6.1 Cooling Startup

1. Turn thermostat to OFF and turn power to ON
2. Turn ON thermostat and set as high as possible
3. Turn Fan switch ON and indoor blower should run
4. Turn fan switch to AUTO, system switch to COOL and thermostat temperature setting below room temperature
Unit should run in COOLING mode.

6.2 Heating Startup

After normal cooling run:

1. Turn thermostat switch to HEAT. After unit stops, wait about 5 minutes.
2. Turn thermostat setting above room temperature.

Unit should run in HEATING mode.

After unit has run for a while, check the following:










1. Are fans running properly?
2. Is compressor running correctly?
3. Check refrigerant charge.
4. Check duct connection for leaks.
5. Check for tubing and sheet metal rattles.

(See Wiring Diagram for electric connection detail.)








WARNING

Component trouble shooting requires opening control box with power on. Use extreme care while working on this condition. Check nameplate and this instruction when making wire connections.

7.1 Fault Code of Motor Driver Module

LED1 Error Code		Content	
	Steady On	Automatic Defrost	
	OFF	Reserved	
	Keep Flashing	2s On 2s Off	Standby
		0.2s On 0.2s Off	Inter-Integrated Circuit Communication Error
	1 Flash/Cycle	Motor Current Error	
	2 Flash/Cycle	Inverter Module Temperature Error	
	3 Flash/Cycle	DC Bus Voltage Error	
	4 Flash/Cycle	Motor Parameter Error	
	5 Flash/Cycle	Motor Startup Failure	
	6 Flash/Cycle	Phase Sequence Error	

7.2 Fault Code of Main Driver Module

LED2 Error Code		Content
	Steady On	Normal Operation
	OFF	Power Supply Failure
	1 Flash/Cycle	T3 Sensor Failure
	2 Flash/Cycle	T4 Sensor Failure
	3 Flash/Cycle	LPC Open
	5 Flash/Cycle	OFM Failure
	6 Flash/Cycle	No Machine Type

7.3 Troubleshooting Table

System Faults	What to Check Mode	Power Supply	High Voltage Wiring	I.D. Control Def.	Compressor Capacitor	O.D. Fan Capacitor	I.D. Blower Capacitor	Contactors Contacts	Low Voltage Wiring	Control Transformer	Thermostat	Contactors Coil	Low Voltage Fuse	Stuck Compressor	Inefficient Compressor	Ref. Undercharge	Ref. Overcharge	Excessive Evap. Load	Noncondensables	Res. O.D. Airflow	O.D. Air Recirculation	TXV Stuck Open	Superheat	Res. I.D. Airflow	Ref. Cir. Restricting	Sov Leaking	Sov Coil Defective	Check Valve Leaking	LPC Sensor Def.	Defrost Control Def.	T4 Temp. Sensor Def.	T3 Temp. Sensor Def.	HPC/HGS Sensor Def.						
Refrigerant Circuit																																							
Head Pressure Too High	C																P	P	S	P	S					S													
	H																P	P	S						P	S													
Head Pressure Too Low	C													S	P								S	S		S	S		P										
	H													S	P								S	S		S	S	S	P										
Suction Pressure Too High	C													S		P	P						S				P		P										
	H													S									S				P												
Suction Pressure Too Low	C															P							S	P	S														
	H															P						S	S		S			S											
Liquid Refr. Floodback (TXV)	C																						P					P											
	H																						P					P											
I.D. Coil Frosting	C															P					S	S																	
	H																																						
Inadequate Compressor Op. or No Cooling/ Heating	C													S	P		S	S					S	P	S	S	S	S											
	H													S	P		S						S	P	S	S	S	S											
Electrical																																							
Compressor & O.D. Fan Won't Start	C	P	P				S	S	P	S	P	P																											
	H	P	P				S	P	S		P																									S	S	S	S
Compressor Will Not Start but O.D. Fan Runs	C		P		P											P																							
	H		P		P		S				P	P																								S		S	
O.D. Fan Won't Start	C		P		P																																		
	H		P		P																															S			
Compressor Hums But Won't Start	C				P		S									P																							
	H				P		S									P																							
I.D. Blower Won't Start	C	P	P	S		P	S	P	S		S																												
	H	P	P	S		P	S	P	S		S																												
Defrost																																							
Unit Won't Initiate Defrost	C																																						
	H																											P							P		S		
Defrost Terminates on Time	C																																						
	H															P																				P		S	
Unit Icing Up	C																																						
	H															P					S	S			S			P					P						

C- Cooling
H- Heating
P- Primary Causes
S- Secondary Causes



MRCOOL®
COMFORT MADE SIMPLE

VersaPro™

Packaged Heat Pump

Installation Manual

The design and specifications of this product and/or manual are subject to change without prior notice.
Consult with the sales agency or manufacturer for details.